

Certificate

Applicant: **KOSTAL Solar Electric GmbH**
Hanferstr. 6
79108 Freiburg i. Br.
Germany

Product: **Photovoltaic Inverter**

Model: **PIKO 20, PIKO 17, PIKO 15**

Intended use:

Automatic disconnection device with three-phase mains surveillance in accordance with VDE 0126-1-1 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

DIN VDE 0126-1-1 (VDE V 0126-1-1):2013-08

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 13KFS114-02

Certificate No: 17-158-00

Date of issue: 2017-05-02



A handwritten signature in black ink, appearing to read "A. Aufmuth", is positioned above the name of the certification body.

Andreas Aufmuth
Certification Body

