

Certificate

Applicant: **KOSTAL Solar Electric GmbH**
Hanferstr. 6
79108 Freiburg i. Br.
Germany

Product: **Photovoltaic Inverter with integrated automatic disconnection device between a generator and the public low-voltage grid**

Model:	PIKO 10	PIKO 12
Rating:	10,0kW	12,0kW

Intended use:

An automatic disconnection device with three-phase mains surveillance in accordance with Engineering Recommendation G59/3 for photovoltaic systems with a three-phase parallel coupling via an inverter to the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

Engineering Recommendation G59/3-2
Issue 3 Amendment 2 September 2015

Recommendations for the connection of generating plant to the distribution systems of licensed distribution network operators

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 13KFS114-15

Certificate No: 17-188-00

Date of issue: 2017-05-17



A handwritten signature in black ink, appearing to read "A. Aufmuth", is positioned above the name of the certification department.

Andreas Aufmuth
Certification Department

