

France VFR2013/2014 Self-Declaration

The company

KOSTAL Solar Electric GmbH
Hanferstraße 6
79108 Freiburg i. Br., Deutschland

hereby declares that for the following inverters:


**PIKO 3.0, 4.2, 4.6, 5.5, 7.0, 8.5, 10, 12, 15, 17, 20
from FW 5.00**

Satisfy the requirements of the norm DIN VDE 0126-1-1/A1-2012-02 with a disconnecting frequency from the public grid at 50.4 HZ or 50.6 HZ, if one of the following country settings are selected at the moment of commissioning

- France VFR 2013 (disconnection at 50.4 HZ) (not available in all power classes)
- France VFR 2014 (disconnection at 50.6 HZ)

This declaration applies to all identical specimens of the product. This declaration becomes invalid if a change is made to the unit or the unit is improperly installed.

KOSTAL Solar Electric GmbH – 2015-07-01



i. V. Werner Palm
(Managing Director)



ppa. Dr. Armin von Preetzmann
(Vicepresident R&D)

This declaration certifies compliance with the harmonisation legislation provisions named, but does not contain any assurance of properties. Observe the safety instructions in the enclosed product documentation!