

Self-Declaration RCD

The company

KOSTAL Solar Electric GmbH
Hanferstraße 6
79108 Freiburg i. Br., Deutschland

herby declares, that the inverters for connection to the low voltage grid

PIKO 1.5 MP, 2.0 MP, 2.5 MP, 3.0 MP, 3.6 MP, 4.2 MP

do not - in terms of their construction - inject continuous ground fault currents.

According to

IEC 62109-1:2010 (cl. 7.3.8)

IEC 60364-7-712:2002 (cl. 712.413.1.1.1.2)

DIN VDE 0100-712:2006 (cl. 712.413.1.1.1.2)

there is no requirement that the differential protection installed downstream of the inverter shall be type B in accordance with IEC 60755/A2.

This declaration applies to all identical specimens of the product. This declaration becomes invalid if a change is made to the unit or the unit is improperly installed.

KOSTAL Solar Electric GmbH – 2017-11-24



i. V. Werner Palm
(Managing Director)



ppa. Dr. Armin von Preetzmann
(Vicepresident R&D)

This declaration certifies compliance with the harmonisation legislation provisions named, but does not contain any assurance of properties. Observe the safety instructions in the enclosed product documentation!