

Self-Declaration

The company

KOSTAL Solar Electric GmbH
Hanferstraße 6
79108 Freiburg i. Br., Germany

hereby declares, that the inverters for connection to the low voltage grid

**PIKO 4.2, PIKO 4.6, PIKO 5.5, PIK 7.0, PIKO 8.5,
PIKO 10, PIKO 12, PIKO 17, PIKO 20**

fulfil the applied standards and guidelines for the EN50438:2013.

Intended use:

Automatic disconnection device with three-phase mains surveillance for photovoltaic system with three-phase parallel coupling via an inverter in public mains supply. the automatic disconnection device is an integrated part of the aforementioned inverter.

Applied standards and guidelines: EN 50438:2013

Requirements for the connection of micro-generators in parallel with public low-voltage distribution networks.

The safety concept of an aforementioned representative product corresponds at the time of issue of the self declaration to the valid safety specifications for the specified use in accordance with regulations.

KOSTAL Solar Electric GmbH – Freiburg, 29.06.2018



Dr. Manfred Gerhard
(Managing Director)



ppa. Dr. Armin von Preetzmann
(Vicepresident R&D)