

Self-Declaration „Zero Feed-In“

The company

KOSTAL Solar Electric GmbH
Hanferstraße 6
79108 Freiburg i. Br., Deutschland

hereby declares, that the following products for connection to the low voltage grid

PIKO MP plus **1.5-1, 2.0-1, 2.5-1, 3.0-1, 3.0-2, 3.6-1, 3.6-2, 4.6-2, 5.0-2**

are compatible with the energy meters listed in the manual „PIKO MP / PIKO MP plus - Energy meters“, which you can find under Download > Product > operation manual.

The inverters supports the „Zero Feed-In“ operation and can be adjusted so that the feed in power to the grid is limited from 0W to the rated power of the inverter.

This declaration applies to all identical specimens of the product. This declaration becomes invalid if a change is made to the unit or the unit is improperly installed.

KOSTAL Solar Electric GmbH – 2020-05-18


KOSTAL
Industrie- und
Lange Eck 11 · 58099 Hagen

Dr. Manfred Gerhard
(Managing Director)



ppa. Dr. Armin von Preetzmann
(Vicepresident R&D)

This declaration certifies compliance with the harmonisation legislation provisions named, but does not contain any assurance of properties. Observe the safety instructions in the enclosed product documentation!