



BUREAU
VERITAS

Verklaring van geen bezwaar

Aanvrager:	KOSTAL Solar Electric GmbH Hanferstraße 6 79108 Freiburg i. Br. Duitsland
Product:	Fotovoltaïsche omvormers en batterij-omvormers
Model:	PIKO MP plus 1.5-1, PIKO MP plus 2.0-1, PIKO MP plus 2.5-1, PIKO MP plus 3.0-1, PIKO MP plus 3.0-2, PIKO MP plus 3.6-1, PIKO MP plus 3.6-2, PIKO MP plus 4.6-2; PIKO MP plus 5.0-2

À utiliser conformément aux réglementations:

Automatisch schakelstation met enkelfasige netwerkbewaking conform C10/11 – 01.09.2019 voor fotovoltaïsche installaties met een enkelfasige parallelvoeding door middel van gelijkstroom-wisselstroommutator in het net van de openbare voorziening. Het automatische schakelstation vormt een integraal bestanddeel van de hoger vermelde gelijkstroom-wisselstroommutators.

Controlebasis:

EN 50549-1:2019-02

Exigences relatives aux centrales électriques destinées à être raccordées en parallèle à des réseaux de distribution - Partie 1: Raccordement à un réseau de distribution BT - Centrales électriques jusqu'au Type B inclus

- 4.4 Normaal werkbereik
- 4.5 Immunité pour störungen
- 4.6 Actieve reactie op frequentieafwijking
- 4.7 Vermogensreactie op spanningsvariaties en spanningsveranderingen
- 4.8 EMC en vermogenskwaliteit
- 4.9 Interfacebescherming
- 4.10 Aansluiting en starten met het opwekken van elektrische stroom
- 4.11 Stoppen en verminderen van actief vermogen op instelpunt
- 4.12 Informatie-uitwisseling op afstand
- 4.13 Vereisten met betrekking tot tolerantie voor één fout van interfacebeveiligingssysteem en interfaceschakelaar

C10/11:2019-09

Specifieke technische voorschriften voor elektriciteitsproductie-installaties die parallel werken met het distributienet

Een representatief testpatroon van het hoger vermelde product voldoet aan de op het moment van de uitreiking van dit attest geldende veiligheid technische eisen van de vermelde controlegrondbeginselen voor een reglementair voorgeschreven gebruik.

Rapportnummer:	18TH0316-PIKO-Hybrid- EN50549-1_1	Certificatie-programma:	NSOP-0032-DEU-ZE-V01
Certificaatnummer:	U20-0391	Datum:	2020-06-08



Certificatie-instelling Bureau Veritas Consumer Products Services Germany GmbH geaccrediteerd volgens DIN EN ISO/IEC 17065

Een gedeeltelijke weergave van het certificaat vereist de schriftelijke goedkeuring van Bureau Veritas Consumer Products Services Germany GmbH



Annex to the EN 50549-1 / C10/11 certificate of compliance No. U20-0391

Appendix

Extract from test report according to EN 50549-1 / C10/11

Nr. 18TH0316-PIKO-Hybrid-EN50549-1_1

Type Approval and declaration of compliance with the requirements of EN 50549-1 / C10/11.

Manufacturer / applicant:	KOSTAL Solar Electric GmbH Hanferstraße 6 79108 Freiburg i. Br. Duitsland							
Type Approval and declaration of compliance with the requirements of EN 50549-1 / C10/11.								
Micro-generator Type	Grid-tied photovoltaic inverter							
	PIKO MP plus 1.5-1	PIKO MP plus 2.0-1	PIKO MP plus 2.5-1	PIKO MP plus 3.0-1				
MPP DC voltage range [V]	75-360	75-360	75-360	125-600				
Input DC voltage range [V]	Max 450	Max 450	Max 450	Max 750				
Input DC current [A]	13	13	13	13				
Output AC voltage [V]	230; N; PE							
Output AC current [A]	12	12	14	14				
Output power [VA]	1500	2000	2500	3000				
	PIKO MP plus 3.0-2	PIKO MP plus 3.6-1	PIKO MP plus 3.6-2	PIKO MP plus 4.6-2				
MPP DC voltage range [V]	125-600	125-600	150-600	150-600				
Input DC voltage range [V]	Max 750							
Input DC current [A]	13	13	13	13				
Output AC voltage [V]	230; N; PE							
Output AC current [A]	14	16	16	20				
Output power [VA]	3000	3680	3680	4600				
	PIKO MP plus 5.0-2							
MPP DC voltage range [V]	150-600							
Input DC voltage range [V]	Max 750							
Input DC current [A]	13							
Output AC voltage [V]	230; N; PE							
Output AC current [A]	22							
Output power [VA]	5000							
Firmware version	PU_APP_3.7.0 and PAR_23.0.2 or higher							
Measurement period:	2019-11-11 to 2020-05-18							
Description of the structure of the power generation unit:								
The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.								



Annex to the EN 50549-1 / C10/11 certificate of compliance No. U20-0391

Appendix

Extract from test report according to EN 50549-1 / C10/11

Nr. 18TH0316-PIKO-Hybrid-EN50549-1_1

Setting of the interface protection:			
Parameter	Max. disconnection time	Min. operate time	Trip value
Over voltage (stage 1) ^a	0,2s	-	230V +10% (253V)
Over voltage (stage 2)	0,2s	0,1s	230V +15% (264,5V)
Under voltage	0,2s	0,1s	230V -20% (184V)
Over frequency	0,2s	0,1s	50Hz +3% (51,5Hz)
Under frequency	0,2s	0,1s	50Hz -5% (47,5Hz)
Reconnection settings for voltage (normal operational startup)	0,85V _n (195,5V) ≤ V ≤ 1,10V _n (253V)		
Reconnection settings for frequency (normal operational startup)	49,9Hz ≤ f ≤ 50,1Hz		
Reconnection time (normal operational startup)	≥ 60s		
Active power gradient (normal operational startup)	20% P _{Emax} / per minute		
Reconnection settings for voltage (automatic reconnection after tripping)	0,85V _n (195,5V) ≤ V ≤ 1,10V _n (253V)		
Reconnection settings for frequency (automatic reconnection after tripping)	49,9Hz ≤ f ≤ 50,1Hz		
Reconnection time (automatic reconnection after tripping)	≥ 60s		
Active power gradient after reconnection	10% P _{Emax} / per minute		
Active power delivery at under frequency	electronic inverter, no active power reduction		
Power response to over frequency (frequency / droop s)	50,2Hz / 5%		
Permanent DC-injection	0,5% of rated inverter output current or 20mA		
Rate of change of frequency (ROCOF)	2Hz/s		
Loss of mains according EN 62116 (LoM)	2,0s		

Note:

^a Over voltage – stage1: 10 min-mean-value corresponding to EN 50160.

Default interface setting according to C10/11:2019-09 are used.

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 and C10/11:2019. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the EN 50549-1:2019 and C10/11:2019.