

**Self-Declaration
to TIGO TS4 modules**

The company

KOSTAL Solar Electric GmbH
Hanferstraße 6
79108 Freiburg i. Br., Germany

hereby declares, that the following products

**PLENTICORE plus, PLENTICORE plus G2, PIKO IQ,
PLENTICORE G3, PLENTICORE MP G3**

are operationally compliant with the following TS4 products from Tigo:

- TS4-A-M Monitoring
- TS4-A-F Rapid Shutdown
- TS4-A-2F Rapid Shutdown
- TS4-S Monitoring, Rapid Shutdown
- TS4-A-S Monitoring, Schnellabschaltung/Rapid Shutdown
- TS4-O Optimization, Monitoring, Rapid Shutdown
- TS4-A-O Optimization, Monitoring, Rapid Shutdown

The combinations have been tested by validating the effective performance of the systems together within standard testing conditions. Warranties from KOSTAL Solar Electric GmbH and Tigo will remain valid if the design, installation, and operation requirements are followed for each product. If TIGO products with an optimizer function are used, the integrated shadow management in the inverter must be deactivated.

If you have questions about equipment or additional TIGO components, contact Tigo Support.

KOSTAL Solar Electric GmbH – Freiburg, 26.05.2025


KOSTAL
KOSTAL Solar Electric GmbH
Hanferstraße 6
D-79108 Freiburg
Tel.: 0761-47744100
Fax: 0761-47744111

Frank Henn
(Managing Director)


KOSTAL
KOSTAL Solar Electric GmbH
Lange Eck 11 • 53099 Hagen

i.V. Frank Greizer
(Head of Department R&D)